GlobTek, Inc. www.globtek.com	Drawing Title: Australia AS/NZS 3112 with ground pin (Type I) to IEC60320 C13 2 CONDUCTORS + GROUND, GT Cable #202: 1.0mmsq / 3 Conductors, 6.8mm OD, GTSA or H05VV-F, 70 Deg.C, 250V, BLU/BRN/GRN-YW, Approvals: SAA/RCM, 2500mm, GlobTek Black		
•	Model No. Power Cord		
Northvale, NJ 07647			
Tel. (201) 784-1000	Part No./Ordering No. 5502022M5701A(R)	Rev E1	
Fax (201) 784-0111			

In Addition to GlobTek Inc.'s renewed ISO9001:2008 - Quality Management System Certification, GlobTek Inc. is now certified to:

ISO13485:2003 - Medical Devices Quality Management System Certification

ISO14001:2004 - Environmental Management System Certification

ISO Certificates are available online at https://www.globtek.com/iso-certificates/

Prop 65 Statement:https://en.globtek.com/prop-65-statement.pdf

The acceptance of this specification and use of the product described in this document indicates the acceptance and binding of the customer to Globtek TERMS AND CONDITIONS (attached to the end of this document), which supersede all other agreements, terms, and conditions (https://en.globtek.com/terms-and-conditions/).

The purchaser of this product (Customer) agrees that it is their sole responsibility to determine suitability/fitness of the product described in this specification for their application and to take precautions for protection against any hazards attendant to the handling and use of the product.

#### Footnote:

GlobTek Inc. will not be liable for the safety and performance of these power supplies if unauthorized access and repair occurs. End user should consult applicable UL, CSA or EN standards for proper installation instruction.

#### Limitation of Use:

GlobTek products are intended for use with commercial, medical, and/or industrial equipment only. GlobTek product are not authorized for use as mission critical components in life support hazardous environment, nuclear or aircraft applications without prior written approval from the CEO of GlobTek Inc.

Contents of this document are subject to change without prior notice.

# **Customer Approval of Specification:**

Please approve, sign and send back to GlobTek so we can complete order processing.

A delay in receipt of this form will delay delivery schedule.

Company Name:	Customer P/N:
Quote Number:	Date:
Authorized Representative Name:	Authorized Representative Signature:

GlobTek, Inc. www.globtek.com	Drawing Title: Australia AS/NZS 3112 with ground pin (Type I) to IEC60320 C13 2 CONDUCTORS + GROUND, GT Cable #202: 1.0mmsq / 3 Conductors, 6.8mm OD, GTSA or H05VV-F, 70 Deg.C, 250V, BLU/BRN/GRN-YW, Approvals: SAA/RCM, 2500mm, GlobTek Black		
•	Model No. Power Cord		
Northvale, NJ 07647			
Tel. (201) 784-1000	Part No./Ordering No. 5502022M5701A(R)	Rev E1	
Fax (201) 784-0111			

## **REVISION HISTORY**

F	REV	DESCRIPTION	SUB	DATE	APPROVED
	E1	Adding test parameters	bsiep	09/17/2021	QA
	E	Update to SF format	bsiep	05/28/2020	QA

Cordset Information:

CordsetColor:GlobTek Black Cord Length (mm):2500

## NOTES:


Insulation Resistance Test: 5MΩ

Hipot Test - wire to wire: AC 2500V@1sec. Hipot Test - wire to shell: AC 4500V@1sec.


Leakage Current Test: 1mA

Standard: IEC60884

GlobTek, Inc.  Www.globtek.com  Drawing Title: Australia AS/NZS 3112 with ground pin (Type I) to IEC60320 C13 2 CONDUCTORS + GROUND, GT Cable #202: 1.0mmsq / 3 Conductors, 6.8mm OD, GTSA or H05VV-F, 70 Deg.C, BLU/BRN/GRN-YW, Approvals: SAA/RCM, 2500mm, GlobTek Black			
•	Model No. Power Cord		
Northvale, NJ 07647			
Tel. (201) 784-1000	Part No./Ordering No. 5502022M5701A(R)	Rev E1	
Fax (201) 784-0111			



GlobTek, Inc. www.globtek.com	RLL/RPN/CPN VW Approvals: SAA/PCM 2500mm ClohTek Black			
	Model No. Power Cord			
Northvale, NJ 07647				
Tel. (201) 784-1000	Part No./Ordering No. 5502022M5701A(R)	Rev E1		
Fax (201) 784-0111				



CIOD I CIX, II IC.	Drawing Title: Australia AS/NZS 3112 with ground pin (Type I) to IEC60320 C13 2 CONDUCTORS + GROUND, GT Cable #202: 1.0mmsq / 3 Conductors, 6.8mm OD, GTSA or H05VV-F, 70 Deg.C, 250V, BLU/BRN/GRN-YW, Approvals: SAA/RCM, 2500mm, GlobTek Black		
•	Model No. Power Cord		
Northvale, NJ 07647			
Tel. (201) 784-1000	Part No./Ordering No. 5502022M5701A(R)	Rev E1	
Fax (201) 784-0111			

End A	Cable	End B
Code:550	Code:202	Code:701SAA
Description: Australia AS/NZS 3112 with ground pin (Type I)	Description:GT Cable #202: 1.0mmsq / 3 Conductors, 6.8mm	Description:IEC60320 C13 2 CONDUCTORS + GROUND
Rating (V):250	OD, GTSA or H05VV-F, 70 Deg.C, 250V, BLU/BRN/GRN-YW	, Rating (V):250
Rating (A):10.0	Approvals: SAA/RCM	Rating (A):10.0
Gender:Male	Color:GlobTek Black	Gender:Female
Overmolded:Yes	Wire Gauge(AWG):1.0mmsq	Overmolded:Yes
	Cond:3	
	Type:GTSA or H05VV-F	
	Temperature:70° C	
	Amps:10	
	Volts:250	
	OD:6.8	
	ConductorsColors:BLU/BRN/GRN-YW	
Overall cable rating:250VAC/10A		


### Cable Approvals Plug Approvals **Connector Approvals € ₹**10 ♠ RCM + European approvals OVE KEUR ER WOOD Note: RCM Logo may be replaced by valid Note: SAA may be indicated **ENEC-VDE** SAA+RCM file number by a file number in the format **NSWxxxxx** Note: SAA may be indicated SAA+RCM by a file number in the format **NSWxxxxxx** AGENCY ONLINE DOCUMENTS http://en.globtek.com/cordsets/ https://www.globtek.com/pdf/rohs\_cert/01t30000002p8dNAAQ RoHS/RoHS3 Declaration

CIOD I CIX, IIIO.	Drawing Title: Australia AS/NZS 3112 with ground pin (Type I) to IEC60320 C13 2 CONDUCTORS + GROUND, GT Cable #202: 1.0mmsq / 3 Conductors, 6.8mm OD, GTSA or H05VV-F, 70 Deg.C, 250V, BLU/BRN/GRN-YW, Approvals: SAA/RCM, 2500mm, GlobTek Black		
•	Model No. Power Cord		
Northvale, NJ 07647			
Tel. (201) 784-1000	Part No./Ordering No. 5502022M5701A(R)	Rev E1	
Fax (201) 784-0111			

op 65 Statement https://en.globtek.com/prop-65-statement.pdf	REACH Declaration	https://www.globtek.com/pdf/iso_certificates/REACH.pdf
E.UKCA.Cord https://globtek.secure.force.com/spec/ec_decl_product_model_family_incl_cord?id=01t30000002p8dN	Conflict Minerals Declaration	https://www.globtek.com/pdf/conflict-minerals.pdf
	Prop 65 Statement	https://en.globtek.com/prop-65-statement.pdf
XY rating is based on 3rd party testing and customers should check suitability and test system level IPXY rating before ordering.	CE.UKCA.Cord	https://globtek.secure.force.com/spec/ec_decl_product_model_family_incl_cord?id=01t30000002p8dN
	PXY rating is based on 3rd party testing	g and customers should check suitability and test system level IPXY rating before ordering.

CIOD I CIX, IIIC.	Drawing Title: Australia AS/NZS 3112 with ground pin (Type I) to IEC60320 C13 2 CONDUCTORS + GROUND, GT Cable #202: 1.0mmsq / 3 Conductors, 6.8mm OD, GTSA or H05VV-F, 70 Deg.C, 250V, BLU/BRN/GRN-YW, Approvals: SAA/RCM, 2500mm, GlobTek Black		
186 Veterans Drive,	Model No. Power Cord		
Northvale, NJ 07647			
Tel. (201) 784-1000	Part No./Ordering No. 5502022M5701A(R)	Rev E1	
Fax (201) 784-0111			

Hanking:200 Description:200 +/- 20mm Image:



Notes/Modifications/Customizations (notes in this section supersede the values shown in the standard spec):